## **FIRE SAFETY CERTIFICATE**

APPENDIX XII

NO: 231/2024

R.C.NO: 773 / V /2024

DATE: 12.09.2024

Certified that the RAJAJI VIDYALAYA SENIOR SECONDARY at T.S.NO. 1\2, 2, 4 & NO.35B, NEW NO 73, TENNUR HIGH ROAD, TENNUR, TIRUCHIRAPPALLI, TAMILNADU Comprised of BLOCK-1 (GROUND FLOOR, FIRSTFLOOR) BLOCK-2 (GROUND FLOOR, FIRSTFLOOR, SECOND FLOOR) Owned by RAJAJI VIDYALAYA SENIOR SECONDARY, have complied with the fire prevention and the fire safety requirements in accordance with rule of state Fire Service, and verified by P.SATHIYAVARTHANAN,B.SC.,B.L., ASSISTANT DISTRICT OFFICER, on 12.09.2024 in the presence of CORRESPONDENT, RAJAJI VIDYALAYA SENIOR SECONDARY, NO.35B, NEW NO 73, TENNUR HIGH ROAD, TENNUR, TIRUCHIRAPPALLI, TAMILNADU And that the building is fits for occupancy up to classes PREKG to XII With effect from 12.09.2024 for a period of ONE YEAR in accordance with rule and subject to compliance of specific conditions as appended:-

## **CONDITIONS**

- (i) SHOULD NOT EXCEED 1750 NO OF STUDENTS
- (ii) AS PER NATIONAL BUILDING CODE 2016 ALL PASSIVE MEASURES SHOULD BE FOLLOWED.
- (iii) NO CHANGES SHOULD BE MADE TO THE SETTINGS IN THE APPROVED PLAN.
- (vi) AS PER NATIONAL BUILDING CODE 2016 ALL FIRE FIGHTING EQUIPMENTS SHOULD BE INSTALLED AND MAINTAIN PROPERLY. SHOULD BE DESIGNATE A PERSON RESPONSIBLE FOR FIRE AND LIFE SAFETY. SHOULD BE CONDUCT BASIC FIRE FIGHTING AND EVACUATION DRILL AND FIRE MOCK DRILL ONCE IN THREE

MONTHS.

Signature with Seal

Name: P.SATHYAVARTHANAN, B.SC., B.L.,

Designation: ASSISTANT DISTRICT OFFICER.

Name & Address of Department/Office: TAMIL NADU FIRE AND RESCUE SERVICE,
TIRUCHIRAPPALLI STATION

TO: CORRESPONDENT,
RAJAJI VIDYALAYA SENIOR SECONDARY,
TENNUR HIGH ROAD, TENNUR,
TIRUCHIRAPPALLI-620017 TAMILNADU.

COPY TO: DISTRICT OFFICER, TAMIL NADU FIRE AND RESCUE SERVICE, TIRUCHIRAPPALLI DISTRICT

## **ENDORSEMENT**

| THE NO OBJECTION CERTIFICATE ISSUED BY FIRE SERVICE STAND CANCELLED AND ANNULLED DUE |
|--|
| ТО   |
|  |
| ( REASONS TO BE  |
| RECORDED) (NAME AND DESIGNATION OF THE AUTHORISED SIGNATORY)                         |